
302 B - 11

Commercial Complax, Ranjeet Nagar, New Delhi- 110008

Phone 011 - 25700168, 9099554242

email: dwtl@watersupermart.com • www.delhiwatertestlab.com







COMPANY

TEST GERTIFICATE

Kalyani Foods Village-Chakdah, Post Madhubani Sadar, Ma Receipt: 05/01/24 by: Party Parameters Color Odor Taste	Types of water Units	wer House), ar-847211 : Drinking Water Test Results		Nil IS:10500-2012 DWGTL/23-24/162 CB 05/01/24 TO 08/01/24 Test method Used
Madhubani Sadar, Ma Receipt: 05/01/24 by: Party Parameters Color Odor	Types of water Units	: Drinking Water Test Results	Lab code: Testing Duration:	DWGTL/23-24/162 CB 05/01/24 TO 08/01/24
Parameters Color Odor	Units	Test Results	Testing Duration :	05/01/24 TO 08/01/24
Parameters Color Odor	Units	Test Results		
Color	2		Requirements	Test method Used
Odor		<1		
			5	IS:3025 Pt-4-2002
Taste		Agreeable	Agreeable	IS:3025 Pt-5-2012
		Agreeable	Agreeable	IS:3025 Pt-8-2006
Turbidity, NTU	NTU	0.4	1	IS:3025 Pt-10-2006
pH	*****	7.62	6.5-8.5	IS:3025 Pt-11-2002
Total Dissolved Solid	mg/l	156	500	IS:3025 Pt-16-2003
Total Iron as Fe	mg/l	0.07	0.3	IS:3025 Pt-53-2009
Total Hardness	mg/l	44	200	IS:3025 Pt-21-2009
Chlorides as Cl	mg/l	32.6	250	IS:3025 Pt-32-2002
Residual Free chlorine,	mg/l	Nil	0.2	IS:3025-Pt26-2003
Sulphate as SO ₄	mg/I	14.3	200	IS:3025pt-24-2009
Fluorides as F-	mg/l	0.15	1.0	IS:3025-Pt60-2003
Coli form	MPN/100ml	Absent	Absent	IS:1622,1981(2003
E.Coli	MPN/100ml	Absent	Absent	IS:1622,1981(2003
	Fluorides as F- Coli form E.Coli ARKS: : With respe	Fluorides as F- mg/l	Fluorides as F- mg/l 0.15	Fluorides as F- mg/l 0.15 1.0 Coli form MPN/100ml Absent Absent E.Coli MPN/100ml Absent Absent

Grangh Checked by Sr. Chemist

Authorized signatory

WE UNDERTAKE TESTING OF: WATER * AIR * EFFLUENTS * MATERIALS

The above result are related only to the sample. Endorsement of products is neither inferred nor implied, this report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media with out our special written permission. Samples will be destroyed after 15 days from the date of reporting unless otherwise specified.

Total liability of laboratory is limited to the invoiced amount

Approved by the Municipal Coporation of Delhi (Health Deptt)